



Company Name	El Mystico & Janet	Project Title	Twenty-five story block
Group/Team Name	Design by Hypnosis	Subtitle	Something completely different
Designer	Mr. Wymer	Job Number	1.1.2.3.2
Date	20 /06 /2018	Client	Mr. Clement Onan

Design Conclusion

End Plate	Fail
------------------	-------------

End Plate

Connection Properties

Connection

Connection Title	Flexible End Plate
Connection Type	Shear Connection

Connection Category

Connectivity	Beam-Beam
Beam Connection	Welded
Column Connection	Bolted

Loading (Factored Load)

Shear Force (kN)	220
------------------	-----

Components

Column Section	WPB 450x300x99.7
Material	Fe 410
Beam Section	UB 356 x 171 x 67
Material	Fe 410
Hole	STD
Plate Section	217X178X14
Thickness (mm)	14
Width (mm)	178
Depth (mm)	217
Hole	STD

Weld

Type	Double Fillet
Size (mm)	12

Bolts

Type	Friction Grip Bolt
Grade	10.9
Diameter (mm)	24
Bolt Numbers	4
Columns (Vertical Lines)	1
Bolts Per Column	2

Gauge (mm)	0
Pitch (mm)	139
End Distance (mm)	39
Edge Distance (mm)	39
Assembly	
Column-Beam Clearance (mm)	14



Company Name	El Mystico & Janet	Project Title	Twenty-five story block
Group/Team Name	Design by Hypnosis	Subtitle	Something completely different
Designer	Mr. Wymer	Job Number	1.1.2.3.2
Date	20 /06 /2018	Client	Mr. Clement Onan

Design Preferences

Bolt

Hole Type	Standard
Hole Clearance (mm)	2.0
Material Grade (MPa) (overwrite)	1040.0
Slip factor	0.48

Weld

Type of Weld	Shop weld
Material Grade (MPa) (overwrite)	410.0

Detailing

Type of Edges	Rolled, machine-flame cut, sawn and planed
Minimum Edge-End Distance	1.5 times the hole diameter
Are members exposed to corrosive influences?	No

Design

Design Method	Limit State Design
---------------	--------------------



Company Name	El Mystico & Janet	Project Title	Twenty-five story block
Group/Team Name	Design by Hypnosis	Subtitle	Something completely different
Designer	Mr. Wymer	Job Number	1.1.2.3.2
Date	20 /06 /2018	Client	Mr. Clement Onan

Design Check			
Check	Required	Provided	Remark
Bolt shear capacity (kN)		$V_{dsf} = ((0.48 \cdot 1 \cdot 1.0 \cdot 256.984) / (1.25)) = 94.886$ [cl. 10.4.3]	
Bolt bearing capacity (kN)		N/A	
Bolt capacity (kN)		94.886	Pass
Critical bolt shear (kN)	≤ 94.886	55.0	Pass
No. of bolts		4	
No. of column(s) per side of end plate	≤ 2	1	
No. of bolts per column per side of end plate		2	
Bolt pitch (mm)	$\geq 2.5 \cdot 24 = 60, \leq \text{Min}(32 \cdot 9.1, 300) = 292$ [cl. 10.2.2]	139	Pass
Bolt gauge (mm)	$\geq 2.5 \cdot 24 = 60, \leq \text{Min}(32 \cdot 9.1, 300) = 292$ [cl. 10.2.2]	0	
End distance (mm)	$\geq 1.5 \cdot 26.0 = 39, \leq 12 \cdot 9.1 = 109.2$ [cl. 10.2.4]	39	Pass
Edge distance (mm)	$\geq 1.5 \cdot 26.0 = 39, \leq 12 \cdot 9.1 = 109.2$ [cl. 10.2.4]	39	Pass
Block shear capacity (kN)	≥ 220	$V_{db} = 212$ [cl. 6.4.1]	Fail
Plate thickness (mm)	≥ 8	14	Pass
Plate height (mm)	$\geq 0.6 \cdot 363.0 = 217.8, \leq 363.0 - 15.7 - 10.2 - 13.5 - 2.7 - 5 = 315.9$ [cl. 10.2.4, Insdag Detailing Manual, 2002]	217	Pass
Plate Width (mm)	$\geq 178, \leq 218$	178	Pass
Effective weld length on each side (mm)		$217 - 2 \cdot 12 = 193$	
		$f_v =$	

Weld strength (kN/mm)	0.568	$(0.7 \cdot 12 \cdot 410) / (\sqrt{3} \cdot 1.25 \cdot 1000)$ = 1.591 [cl. 10.5.7]	Pass
------------------------------	-------	--	-------------



Company Name	El Mystico & Janet	Project Title	Twenty-five story block
Group/Team Name	Design by Hypnosis	Subtitle	Something completely different
Designer	Mr. Wymer	Job Number	1.1.2.3.2
Date	20 /06 /2018	Client	Mr. Clement Onan

Views



Company Name	El Mystico & Janet	Project Title	Twenty-five story block
Group/Team Name	Design by Hypnosis	Subtitle	Something completely different
Designer	Mr. Wymer	Job Number	1.1.2.3.2
Date	20 /06 /2018	Client	Mr. Clement Onan

Additional Comments	This is a sample design report generated in Osdag!
----------------------------	--